

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015659
DATE: 07/28/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Lepage
CODE: 422-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Lepage Millwork 141 Chemin des Raymond Riviere-du-Loup, Quebec G5R 4L9 | Series "Wood Awning (A100) 2 1/4" Sash" Wood Awning Window Configuration: X Glazing: IG-Int.-4mm Annealed Glass/Ext.-Laminate-4mm Annealed Glass/0.090" Sentry Glass Plus Interlayer by Dupont/4mm Annealed Glass Frame: W-1219mm(48") H-1219mm(48") Vent: W-1156mm(45.50") H-1156mm(45.50") DLO: W-1054mm(41.50") H-1054mm(41.50") |

| SPECIFICATION | PRODUCT RATING |
|---|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a/14a | Class CW-PG50 1219 x 1219 (48 x 48)-AP Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Wind Zone 3-Missile Level D Large Missile Impact Rated |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-24763-1/NCTL-110-24763-2
Expiration Date: **December 31, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com