

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015660  
**DATE:** 07/28/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Steves and Sons  
**CODE:** 1846-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Steves and Sons Corporation</b> <b>203 Humble Avenue</b> <b>San Antonio, TX 78225</b>	<b>Opaque Outswing Steel</b> <b>Side-Hinged Door Assembly</b>  Configuration: X  Frame: W-959mm(37.75") H-2051mm(80.75") Panel: W-908mm(35.75") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 ASTM E330-14 ASTM E331-00 ASTM E1886-13a ASTM E1996-14a	<b>Design Pressure: ±2394 Pa (±50 psf)</b> <b>Positive Design Pressure: 2394 Pa (50 psf)</b> <b>Negative Design Pressure: 2633 Pa (55 psf)</b> Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01523366  
Expiration Date: March 31, 2026

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)