

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015661.01
DATE: 07/28/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Steves and Sons
CODE: 1846-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Steves and Sons Corporation 203 Humble Avenue San Antonio, TX 78225	Series "Element" Opaque Outswing Steel Side-Hinged Double Door Assembly Configuration: XX Frame: W-1880mm(74") H-2051mm(80.75") Panel: W-908mm(35.75") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 ASTM E330-14 ASTM E331-00 ASTM E1886-13a ASTM E1996-14a	Design Pressure: ±2873 Pa (±60 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Wind Zone 3 - Missile Level D

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01523548 (Specimens 2 & 2a)
Expiration Date: **July 31, 2026**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. M.', is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com