

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015661.02  
**DATE:** 07/28/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Steves and Sons  
**CODE:** 1846-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Steves and Sons Corporation</b> <b>203 Humble Avenue</b> <b>San Antonio, TX 78225</b>	<b>Series "Element"</b> <b>Opaque Outswing Steel</b> <b>Side-Hinged Double Door Assembly</b>  Configuration: X  Frame: W-953mm(37.5") H-2070mm(81.5") Panel: W-908mm(35.75") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04</b> <b>ASTM E330-14</b> <b>ASTM E331-00</b> <b>ASTM E1886-13a</b> <b>ASTM E1996-14a</b>	<b>Design Pressure: ±2873 Pa (±60 psf)</b> <b>Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)</b> <b>ASTM E1886-13a/1996-14a</b> <b>Design Pressure: ±2394 Pa (±50 psf)</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01523548 (Specimens 2, 2b & 2c)  
Expiration Date: **July 31, 2026**

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)