

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015661.03-R1
DATE: 07/28/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Steves and Sons
CODE: 1846-1
DATE: 07/08/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Steves and Sons Corporation 203 Humble Avenue San Antonio, TX 78225 | Series "Element" Opaque Inswing Steel Side-Hinged Door Configuration: X Frame: W-953mm(37.5") H-2070mm(81.5") Panel: W-908mm(35.75") H-2007mm(79") |

| SPECIFICATION | PRODUCT RATING |
|---|--|
| ASTM E283-04 ASTM E330-14 ASTM E331-00 ASTM E1886-13a ASTM E1996-14a | Design Pressure: ±2873 Pa (±60 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Wind Zone 3 - Missile Level D |

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01523548 (Specimens 3, 3a, 3b & 3c)
Expiration Date: **July 31, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com