

Notice of Product Certification

CERTIFICATION NO.: 1642-004
INITIAL CERTIFICATION DATE: August 22, 2022
REVISION DATE: N/A
REPORT NUMBER: SUN22105859-d
SPECIFICATION: CSA A440.2-19

COMPANY: Sunview Windows and Doors
CODE: 1642-1
EXPIRATION DATE: June 14, 2024
PRODUCT SIMULATED BY: WSP Canada Group Ltd.
AIR LEAKAGE REPORT NO.: AI-05045-A1 Rev.1

PRODUCT/SERIES NAME: S-3200 Fixed Picture OPERATOR TYPE: FIXD

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1642-004-0001-01	SG400-arg90-VCI, iu	0.113(#2)	1.64	0.55	0.68	0.0	36
1642-004-0001-02	SG400-arg90-VCI, iu, Grids < 1"	0.113(#2)	1.64	0.50	0.61	0.0	33
1642-004-0002-01	SG400-arg90-VCI-arg90-VCI, iu	0.113(#2)	1.22	0.50	0.62	0.0	42
1642-004-0002-02	SG400-arg90-VCI-arg90-VCI, iu, Grids < 1"	0.113(#2)	1.22	0.45	0.55	0.0	39
1642-004-0003-01	SG400-arg90-VCI-arg90-SG400, iu	0.113(#2, #5)	0.94	0.48	0.59	0.0	47
1642-004-0003-02	SG400-arg90-VCI-arg90-SG400, iu, Grids < 1"	0.113(#2, #5)	0.94	0.43	0.53	0.0	44

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com