

Notice of Product Certification

CERTIFICATION NO.: 1642-006
INITIAL CERTIFICATION DATE: August 22, 2022
REVISION DATE: N/A
REPORT NUMBER: SUN22105859-f
SPECIFICATION: CSA A440.2-19

COMPANY: Sunview Windows and Doors
CODE: 1642-1
EXPIRATION DATE: August 28, 2024
PRODUCT SIMULATED BY: WSP Canada Group Ltd.
AIR LEAKAGE REPORT NO.: AI-03523-D5

PRODUCT/SERIES NAME: S-3450 Single Hung OPERATOR TYPE: VSSH

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1642-006-0001-01	SG400-arg90-VCl, iu	0.113(#2)	1.70	0.48	0.59	0.4	30
1642-006-0001-02	SG400-arg90-VCl, iu, Grids < 1"	0.113(#2)	1.70	0.43	0.53	0.4	27
1642-006-0002-01	SG400-arg90-VCl-arg90-VCl, iu	0.113(#2)	1.60	0.44	0.54	0.4	30
1642-006-0003-01	SG400-arg90-VCl-arg90-SG400, iu	0.113(#2, #5)	1.39	0.42	0.52	0.4	33

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S.M.', is written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com