

Notice of Product Certification

CERTIFICATION NO.: 2858-002
INITIAL CERTIFICATION DATE: August 18, 2022
REVISION DATE: N/A
REPORT NUMBER: QUA18001-12_PRAW
SPECIFICATION: CSA A440.2-19

COMPANY: Aluminium Fenebel 1964, Inc.
CODE: 2858-1
EXPIRATION DATE: September 6, 2023
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-04077-E1

PRODUCT/SERIES NAME: Neo Awning

OPERATOR TYPE: PRAW

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2858-002-0001-01	3mm_7/8_GCl-arg95-8071 im	0.082(#3)	1.55	0.46	0.51	0.2	32
2858-002-0002-01	3mm_7/8_STCl-arg90-8071 sp	0.082(#3)	1.52	0.48	0.52	0.2	34
2858-002-0003-01	3mm_7_8_Clr-arg95-PTLx im	0.082(#3)	1.54	0.47	0.51	0.2	33
2858-002-0004-01	3mm_7_8_Clr-arg97-PTLx ss	0.082(#3)	1.49	0.47	0.51	0.2	34

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'Shi' or similar, written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com