

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015377.01
DATE: 08/08/2022
CERTIFICATION PROGRAM: Structural
COMPANY: United
CODE: 2779-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
United Window & Door Manufacturing 24-36 Fadem Road Springfield, New Jersey 07081	Series "3800-3900/3810-3910" Vinyl Horizontal Sliding Window Configuration: XOX Glazing: Insulated Glass (Annealed) Frame: W-2731mm(107.50") H-1511mm(59.50") Sash: W-679mm(26.75") H-1435mm(56.50") DLO: W-1257mm(49.50") H-1378mm(54.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG15 2731 x 1511 (108 x 60)-HS Design Pressure: 1080 Pa (15 psf) Water Penetration Resistance Test Pressure: 150 Pa (3.13 psf)

Product Tested By: Molimo, LLC
Report No: 1155.13-106-12
Expiration Date: **June 30, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com