

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015379.02
DATE: 08/08/2022
CERTIFICATION PROGRAM: Structural
COMPANY: United
CODE: 2779-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
United Window & Door Manufacturing 24-36 Fadem Road Springfield, New Jersey 07081	Series "3800-3900/3800-3900" Vinyl Triple Single Hung-Fixed- Single Hung Window Configuration: O/XOO/X Glazing: Insulated Glass (Annealed) Frame: W-2743mm(108") H-2019mm(79.50") Sash: W-686mm(27") H-908mm(35.75") DLO: W-625mm(24.63") H-873mm(34.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG25 2743 x 2019 (108 x 80)-H Design Pressure: ±1200 Pa (±25 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested By: Molimo, LLC
Report No: 11552.10-106-12
Expiration Date: **June 30, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com