

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015380.02
DATE: 08/03/2022
CERTIFICATION PROGRAM: Structural
COMPANY: United
CODE: 2779-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
United Window & Door Manufacturing 24-36 Fadem Road Springfield, New Jersey 07081	Series "3800-3900" Vinyl Twin Single Hung Window Configuration: O/XO/X Glazing: Insulated Glass (Annealed) Frame: W-2438mm(96") H-1600mm(63") Sash: W-1137mm(44.75") H-730mm(28.75") DLO: W-1092mm(43") H-724mm(28.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG35 2438 x 1600 (96 x 63)-H Design Pressure: 1680 Pa (35 psf) Positive Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)

Product Tested By: Molimo, LLC
Report No: 11552.07-106-12
Expiration Date: **July 31, 2026**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Molimo", is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com