

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015663.01
DATE: 08/02/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: 052-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "FiberClassic and Smooth Star Glazed Fiberglass Doors with Sidelites" Outswing Glazed Fiberglass Doors (w/Sidelites) Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-3797mm(149.50") H-2064mm(81.25") Panel: W-914mm(36") H-2013mm(79.25") DLO: W-660mm(26") H-1604mm(63.13")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 ASTM E330-14 ASTM E331-00	Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01462919 - Specimen 2
Expiration Date: **December 31, 2024**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com