

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015663.04
DATE: 08/02/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: 052-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517 | Series "FiberClassic and Smooth Star Glazed Fiberglass Doors with Sidelites" Inswing Glazed Fiberglass Doors (w/Sidelites) Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-2858mm(112.50") H-2083mm(82") Panel: W-911mm(35.88") H-2013mm(79.25") DLO: W-530mm(20.88") H-1597mm(62.88") |

| SPECIFICATION | PRODUCT RATING |
|---|--|
| ASTM E283-04 ASTM E330-14 ASTM E331-00 | Design Pressure: 2160 Pa (45 psf) Positive Design Pressure: 2160 Pa (45 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) |

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01462919 - Specimen 5
Expiration Date: **December 31, 2024**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com