

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015663.07  
**DATE:** 08/02/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Therma-Tru  
**CODE:** 052-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Therma-Tru Corporation</b>  <b>118 Industrial Drive</b>  <b>Edgerton, OH 43517</b>	<p style="text-align: center;"><b>Series “FiberClassic and Smooth Star Glazed Fiberglass Doors with Sidelites”</b></p> <p style="text-align: center;"><b>Inswing Glazed Fiberglass Doors</b></p> <p style="text-align: center;"><b>(w/Sidelites)</b></p> <p style="text-align: center;">Configuration: OXO Glazing: Insulating Glass (Tempered)</p> <p>Frame: W-2858mm(112.50")    H-2083mm(82")</p> <p>Panel: W-911mm(35.88")    H-2013mm(79.25")</p> <p>DLO: W-660mm(26")    H-1604mm(63.13")</p>

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04</b> <b>ASTM E330-14</b> <b>ASTM E331-00</b>	<b>Design Pressure: 2160 Pa (45 psf)</b> <b>Positive Design Pressure: 2160 Pa (45 psf)</b> <b>Negative Design Pressure: 2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
 Report No: TEL 01462919 - Specimen 8  
 Expiration Date: **December 31, 2024**

Administrator’s Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
 MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
 Email: [nami@namiinc.com](mailto:nami@namiinc.com)