NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015664-R1

DATE: 08/03/2022

CERTIFICATION PROGRAM: IG

COMPANY: Croft

CODE: 1887-1

REVISION DATE: <u>06/21/2023</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
Croft, LLC	Insulating Glass:	Double Glazed
1800 North Clark Avenue	Sealant:	Hot Melt Butyl
Magnolia, MS 39652	Spacer:	Tin Plated Steel
	Desiccant:	Matrix
	Glass:	Clear/Low-E
	Fill:	Argon
	Muntins:	Yes

SPECIFICATION	PRODUCT RATING
ASTM E2188-19/2189-19/2190-19 NFRC 706-2023 (Gas Fill Requirements)	Passed Meets or Exceeds Gas Fill Requirements
ASTM E2649-20	Certification Mark: NAMI-201887

Product Tested By: PRI Construction Materials Technologies LLC

Report No: 2189T0036

Expiration Date: **January 31, 2025**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122