

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015674.02
DATE: 09/06/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Prime Window
CODE: 2288-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Prime Window Systems 3400 Tacoma Street Union Gap, WA 98903	Series "5000" Vinyl Sliding Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1819mm(71.63") H-2021mm(79.56") Panel: W-908mm(35.75") H-1946mm(76.63") DLO: W-784mm(30.88") H-1829mm(72")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG35 1819 x 2021* (72 x 80*)-SD Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: M4697.01-901-44/M4698.01-901-44
Expiration Date: August 31, 2025

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com