NOTICE OF PRODUCT CERTIFICATION



This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--------------------------|--|
| Builder's Hardware, Inc. | Plastpro 3'0" x 6'8" Glazed |
| 5615 E. Powhatan Ave. | Fiberglass In-Swing Side Hinged Door |
| Tampa, FL 33610 | (w/Sidelites & Composite Jambs) |
| | Configuration: OXO |
| | Frame: W-1743mm(68.63") H-2083mm(82") |
| | Panel: W-908mm(35.75") H-2013mm(79.25") |
| | DLO: W-537mm(21.13") H-1604mm(63.13") |
| | STP: Pos+2298 Pa (48 psf) Neg-2298 Pa (48 psf) |

SPECIFICATION

AAMA 1702.2-95 Federal Manufactured Home Construction & Safety Standard 3280.405

PRODUCT RATING

Manufactured Housing-Passed Wind Zone II Design Wind Pressure Rating: +48/-48 psf

Product Tested By:Testing Evaluation Laboratories, Inc.Report No:TEL 01393402Expiration Date:September 30, 2024

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com