

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015676.06-R1  
**DATE:** 09/07/2022  
**CERTIFICATION PROGRAM:** Mfg Hsg  
**COMPANY:** Builders Hardware  
**CODE:** 435-1  
**REVISION DATE:** 09/07/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Builder's Hardware, Inc.</b> <b>5615 E. Powhatan Ave.</b> <b>Tampa, FL 33610</b>	<b>Plastpro 6'0" x 6'8" Glazed Fiberglass In-Swing Side Hinged Door</b> <b>(w/ Composite Jambs)</b>  Configuration: XX  Frame: W-1880mm(74") H-2083mm(82") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-537mm(21.13") H-1604mm(63.13") STP: Pos+2298 Pa (48 psf) Neg-2298 Pa (48 psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-95 Federal Manufactured Home Construction &amp; Safety Standard 3280.405</b>	<b>Manufactured Housing-Passed Wind Zone II Design Wind Pressure Rating: +48/-48 psf</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01393403  
Expiration Date: **September 30, 2024**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)