

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015678  
**DATE:** 09/22/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "4880"</b> <b>Aluminum Sliding Glass Door</b>  Configuration: XX Glazing: Monolithic-3/16" Annealed Glass/0.090" Kuraray SGP Interlayer/3/16" Annealed Glass or 3/16" Heat Strengthened Glass/0.090" Kuraray SGP Interlayer/3/16" Heat Strengthened Glass or Insulating Glass - 1/8" Tempered Glass/3/16" Heat Strengthened Glass/0.090" Kuraray SGP Interlayer/3/16" Heat Strengthened Glass  Frame: W-2426mm(95.5") H-2426mm(95.5") Panel: W-1238mm(48.75") H-2394mm(94.25") DLO: W-1067mm(42") H-2219mm(87.38")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: <math>\pm 3112</math> Pa (<math>\pm 65</math> psf)</b> <b>Positive Design Pressure: 3112 Pa (65 psf)</b> <b>Negative Design Pressure: 3352 Pa (70 psf)</b> Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf) <b>Large Missile Impact Rated</b>

Product Tested By: Molimo Architectural Product Testing  
Report No: 2077.01-106-11  
Expiration Date: **February 28, 2025**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)