

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015678.01
DATE: 09/22/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151</p>	<p style="text-align: center;">Series "4880"</p> <p style="text-align: center;">Aluminum Sliding Glass Door</p> <p style="text-align: center;">Configuration: XX Glazing: Monolithic-3/16" Annealed Glass/0.105" Solutia PVB Interlayer/3/16" Annealed Glass or Insulating Glass - 1/8" Tempered Glass/3/16" Heat Strengthened Glass/0.090" Kuraray SGP Interlayer/3/16" Heat Strengthened Glass</p> <p>Frame: W-2426mm(95.5") H-2426mm(95.5") Panel: W-1238mm(48.75") H-2394mm(94.25") DLO: W-1067mm(42") H-2219mm(87.38")</p>

SPECIFICATION	PRODUCT RATING
<p>TAS 201/202/203-94</p>	<p>Design Pressure: ±2633 Pa (±55 psf) Positive Design Pressure: 2633 Pa (55 psf) Negative Design Pressure: 3112 Pa (65 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf) Large Missile Impact Rated</p>

Product Tested By: Molimo Architectural Product Testing
 Report No: 2077.01-106-11
 Expiration Date: **February 28, 2025**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com