

# NOTICE OF PRODUCT CERTIFICATION



**Company:** Masonite International Corporation  
 1955 Powis Road  
 West Chicago, IL 60185

**Certification No.:** NI013717.21-R1  
**Certification Date:** 10/12/2022  
**Expiration Date:** 05/31/2027  
**Revision Date:** 12/06/2023

**Product:** Fiberglass Opaque Inswing or Outswing Door w/ and w/o Impact Rated Sidelites (w/Wood Frame or Worldwide Composite Frame<sup>4</sup> unless noted)

**Specification:** TAS 202-94/ASTM E330-02/14/M-14/ASTM E1886-05/13a/ASTM E1996-09/14a

**Impact:** Missile Level D Impact Glazing: IG-1/8" Tempered Glass/1/8" Heat-Strengthened Glass/0.090 Saflex PVB Interlayer/1/8" Heat-Strengthened Glass

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Opaque	3'0" x 6'8"	+60/-65	0.0 psf	Yes	NCTL-210-3835-1/W-1812/W-1972/W-2106 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0187-17
X Single	O/S	Opaque	3'0" x 6'8"	+60/-60	3.75 psf <sup>1</sup> /6.0 psf <sup>2</sup> 8.25 psf <sup>3</sup> /9.0 psf <sup>5</sup> 7.5 psf <sup>6</sup>	Yes	NCTL-210-3835-1/W-1812/W-1813/W-1843/W-1860/W-1972/W-2106 Maximum Panel Size: 3'0" x 6'8" Anchor Details-MA-FL0187-17
XX Double	I/S	Opaque	6'0" x 6'8"	+50/-50	0 psf	Yes	ATLNC 0831.01-16/ATLNC 0901.02-16/W-1972/W-2106 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0187-17
XX Double	O/S	Opaque	6'0" x 6'8"	+50/-50	3.75 psf <sup>1</sup> /6.0 psf <sup>2</sup> 8.25 psf <sup>3</sup> /8.25 psf <sup>5</sup>	Yes	ATLNC 0831.01-16/ATLNC 0901.02-16/W-1813/W-1843/W-2106 Maximum Panel Size: 3'0" x 6'8" /W-1972 Anchor Details-DWG-MA-FL0187-17
XO/OX Single w/Sidelite	I/S	Opaque Door Glazed Sidelite	6'0" x 6'8"	+50/-50	0 psf	Door-Yes Sidelite-Yes	ATLNC 0831.01-16/ATLNC 0901.02-16/ATLNC 1222.01-15/W-1972/W-2048/W-2106 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA-FL0255-22
XO/OX Single w/Sidelite	O/S	Opaque Door Glazed Sidelite	6'0" x 6'8"	+50/-50	3.75 psf <sup>1</sup> /6.0 psf <sup>2</sup> 8.25 psf <sup>3</sup> /9.0 psf <sup>5</sup>	Door-Yes Sidelite-Yes	ATLNC 0831.01-16/ATLNC 0901.02-16/ATLNC 1222.01-15/W-1813/W-1843/W-1972/W-2048/W-2106 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA- FL0255-22
OXO Single w/Sidelites	I/S	Opaque Door Glazed Sidelite	9'0" x 6'8"	+50/-50	0 psf	Door-Yes Sidelites-Yes	ATLNC 0831.01-16/ATLNC 0901.02-16/ATLNC 1222.01-15/W-1972/W-2048/W-2106 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA- FL0255-22
OXO Single w/Sidelites	O/S	Opaque Door Glazed Sidelite	9'0" x 6'8"	+50/-50	3.75 psf <sup>1</sup> /6.0 psf <sup>2</sup> 8.25 psf <sup>3</sup> /9.0 psf <sup>5</sup>	Door-Yes Sidelites-Yes	ATLNC 0831.01-16/ATLNC 0901.02-16/W-1813/ATLNC 1222.01-15/W-1843/W-1972/W-2048/W-2106 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA- FL0255-22
OXXO Double w/Sidelites	I/S	Opaque Door Glazed Sidelite	12'4" x 6'8"	+50/-50	0 psf	Door-Yes Sidelites-Yes	ATLNC 0831.01-16/ATLNC 0901.02-16/ATLNC 1222.01-15/ATLNC 1222.01-15/W-1972/W-2048/W-2106 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA- FL0255-22
OXXO Double w/Sidelites	O/S	Opaque Door Glazed Sidelite	12'4" x 6'8"	+50/-50	3.75 psf <sup>1</sup> /6.0 psf <sup>2</sup> 8.25 psf <sup>3</sup> /8.25 psf <sup>5</sup>	Door-Yes Sidelites-Yes	ATLNC 0831.01-16/ATLNC 0901.02-16/ATLNC 1222.01-15/W-1813/W-1843/W-1972/W-2048/W-2106 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA- FL0255-22

1 -Denotes Bumper Outswing Threshold 2 -Denotes Z-Series Outswing Threshold 3-Hi-Dam Outswing Threshold 4-W-1815 5-Worldwide Pro T4 Threshold 6-Denotes HP Outswing Threshold

**National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072**

**Tel: (804) 684-5124/nami@namiinc.com**

**NAMI AUTHORIZED SIGNATURE:** \_\_\_\_\_