

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015538.02  
**DATE:** 10/13/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Sunset Windows  
**CODE:** 2348-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Sunset Windows and Doors, LLC</b> <b>910 Warehouse Road, Unit 110104</b> <b>Orlando, FL 32803</b>	<b>Series "V-750"</b> <b>Vinyl Single Hung Window</b>  Configuration: O/X Glazing: Mono-3/16" Heat Strengthened Glass/0.090" Kuraray SGP Interlayer/3/16" Heat Strengthened Glass or IG-5/32" Tempered Glass/5/32" Heat Strengthened Glass/0.090 Kuraray SGP Interlayer/5/32" Heat Strengthened Glass  Frame: W-1349mm(53.13") H-1930mm(76") Sash: W-1187mm(46.75") H-965mm(38") DLO: W-1072mm(42.20") H-922mm(36.29")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>ASTM E1886-12/13a</b> <b>ASTM E1996-12/14a</b>	<b>Class CW-PG70 1349 x 1930 (53 x 76)-H</b> <b>Design Pressure: ±3360 Pa (±70 psf)</b> <b>Water Penetration Resistance Level: 540 Pa (11.25 psf)</b> <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4227-03A  
Expiration Date: **October 31, 2025**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shirley".

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)