

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015674.04  
**DATE:** 10/06/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Prime Window  
**CODE:** 2288-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Prime Window Systems</b> <b>3400 Tacoma Street</b> <b>Union Gap, WA 98903</b>	<b>Series "5000"</b> <b>Vinyl Sliding Door</b>  Configuration: XXO Glazing: Insulating Glass (Tempered)  Frame: W-3639mm(143.25") H-2429mm(95.63") Panel: W-1213mm(47.75") H-2354mm(92.69") DLO: W-1092mm(43") H-2235mm(88")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class R-PG15 3639 x 2429 (143 x 96)-SD</b> <b>Design Pressure: ±720 Pa (±15 psf)</b> Water Penetration Resistance Test Pressure: 140 Pa (2.92 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC  
Report No: N4827.02-901-44  
Expiration Date: **July 31, 2026**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)