

Notice of Product Certification

CERTIFICATION NO.: 1473-001
INITIAL CERTIFICATION DATE: November 3, 2022
REVISION DATE: N/A
REPORT NUMBER: AT-00998
SPECIFICATION: CSA A440.2-19

COMPANY: Omega Windows
CODE: 1473-1
EXPIRATION DATE: September 9, 2027
PRODUCT SIMULATED BY: UL Laboratory Canada Inc.
AIR LEAKAGE REPORT NO.: AI-03661-A1

PRODUCT/SERIES NAME: 4600 Panoramic **OPERATOR TYPE:** FIXD

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1473-001-0001-01	SP13_180#2-Arg95-ClrCGI	0.068(#2)	1.55	0.53	0.65	0.0	37
1473-001-0001-02	SP13_180#2-Arg95-ClrCGI_Grids < 1"	0.068(#2)	1.55	0.48	0.59	0.0	34
1473-001-0002-01	SP13_180#2-Arg95-i89#4	0.068(#2) 0.149(#4)	1.29	0.52	0.64	0.0	42
1473-001-0002-02	SP13_180#2-Arg95-i89#4_Grids < 1"	0.068(#2) 0.149(#4)	1.29	0.47	0.57	0.0	39
1473-001-0003-01	SP13_366#2-Arg95-ClrCGI	0.02(#2)	1.47	0.22	0.54	0.0	21
1473-001-0003-02	SP13_366#2-Arg95-ClrCGI_Grids < 1"	0.02(#2)	1.47	0.20	0.48	0.0	19
1473-001-0004-01	SP13_366#2-Arg95-i89#4	0.02(#2) 0.149(#4)	1.23	0.22	0.52	0.0	13
1473-001-0004-02	SP13_366#2-Arg95-i89#4_Grids < 1"	0.02(#2) 0.149(#4)	1.23	0.20	0.47	0.0	25
1473-001-0005-01	SP13_ClrCGI-Arg95-ClrCGI-Arg95-180#5	0.068(#5)	1.16	0.51	0.60	0.0	44
1473-001-0005-02	SP13_ClrCGI-Arg95-ClrCGI-Arg95-180#5_Grids < 1"	0.068(#5)	1.16	0.46	0.54	0.0	41
1473-001-0006-01	SP13_366#2-Arg95-ClrCGI-Arg95-180#5	0.02(#2) 0.068(#5)	0.89	0.20	0.47	0.0	32
1473-001-0006-02	SP13_366#2-Arg95-ClrCGI-Arg95-180#5_Grids < 1"	0.02(#2) 0.068(#5)	0.89	0.18	0.42	0.0	31
1473-001-0007-01	SP13_366#2-Arg95-ClrCGI-Arg95-ClrCGI	0.02(#2)	1.15	0.21	0.49	0.0	27
1473-001-0007-02	SP13_366#2-Arg95-ClrCGI-Arg95-ClrCGI_Grids < 1"	0.02(#2)	1.15	0.19	0.44	0.0	26
1473-001-0008-01	SP13_180#2-Arg95-ClrCGI-Arg95-180#5	0.068(#2, #5)	0.91	0.46	0.58	0.0	47
1473-001-0008-02	SP13_180#2-Arg95-ClrCGI-Arg95-180#5_Grids < 1"	0.068(#2, #5)	0.91	0.42	0.52	0.0	44
1473-001-0009-01	SP13_180#2-Arg95-180#4-Arg95-i89#6	0.068(#2, #4) 0.149(#6)	0.83	0.44	0.56	0.0	47
1473-001-0009-02	SP13_180#2-Arg95-180#4-Arg95-i89#6_Grids < 1"	0.068(#2, #4) 0.149(#6)	0.83	0.40	0.50	0.0	45
1473-001-0010-01	SP13_180#2-Arg95-ClrCGI-Arg95-i89#6	0.068(#2) 0.149(#6)	1.04	0.48	0.59	0.0	45
1473-001-0010-02	SP13_180#2-Arg95-ClrCGI-Arg95-i89#6_Grids < 1"	0.068(#2) 0.149(#6)	1.04	0.43	0.52	0.0	42
1473-001-0011-01	SP13_366#2-Arg95-ClrCGI-Arg95-i89#6	0.02(#2) 0.149(#6)	1.00	0.20	0.48	0.0	30
1473-001-0011-02	SP13_366#2-Arg95-ClrCGI-Arg95-i89#6_Grids < 1"	0.02(#2) 0.149(#6)	1.00	0.19	0.43	0.0	29

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "M.D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com