

# Notice of Product Certification

**CERTIFICATION NO.:** 1473-006

INITIAL CERTIFICATION DATE: November 10, 2022

REVISION DATE: N/A

REPORT NUMBER: AT-01001

SPECIFICATION: CSA A440.2-19

**COMPANY:** Omega Windows

CODE: 1473-1

EXPIRATION DATE: September 9, 2027

PRODUCT SIMULATED BY: UL Laboratory Canada Inc.

AIR LEAKAGE REPORT NO.: NCTL-110-19931-2

**PRODUCT/SERIES NAME:** 4300 ECO 3.25 Single Slider **OPERATOR TYPE:** HSOX

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1473-006-0001-01	SM_180#2-Arg95-ClrCGI	0.068(#2)	1.70	0.50	0.62	0.3	31
1473-006-0001-02	SM_180#2-Arg95-ClrCGI_Grids < 1"	0.068(#2)	1.70	0.45	0.55	0.3	28
1473-006-0002-01	SM_180#2-Arg95-i89#4	0.068(#2) 0.149(#4)	1.45	0.49	0.60	0.3	36
1473-006-0002-02	SM_180#2-Arg95-i89#4_Grids < 1"	0.068(#2) 0.149(#4)	1.45	0.44	0.54	0.3	33
1473-006-0003-01	SM_366#2-Arg95-ClrCGI	0.02(#2)	1.62	0.21	0.50	0.3	16
1473-006-0003-02	SM_366#2-Arg95-ClrCGI_Grids < 1"	0.02(#2)	1.62	0.19	0.45	0.3	15
1473-006-0004-01	SM_366#2-Arg95-i89#4	0.02(#2) 0.149(#4)	1.40	0.21	0.49	0.3	21
1473-006-0004-02	SM_366#2-Arg95-i89#4_Grids < 1"	0.02(#2) 0.149(#4)	1.40	0.19	0.44	0.3	20
1473-006-0005-01	SM_ClrCGI-Arg95-ClrCGI-Arg95-180#5	0.068(#5)	1.34	0.48	0.56	0.3	38
1473-006-0005-02	SM_ClrCGI-Arg95-ClrCGI-Arg95-180#5_Grids < 1"	0.068(#5)	1.34	0.43	0.50	0.3	35
1473-006-0006-01	SM_366#2-Arg95-ClrCGI-Arg95-180#5	0.02(#2) 0.068(#5)	1.09	0.19	0.44	0.3	27
1473-006-0006-02	SM_366#2-Arg95-ClrCGI-Arg95-180#5_Grids < 1"	0.02(#2) 0.068(#5)	1.09	0.18	0.39	0.3	26
1473-006-0007-01	SM_366#2-Arg95-ClrCGI-Arg95-ClrCGI	0.02(#2)	1.32	0.20	0.46	0.3	22
1473-006-0007-02	SM_366#2-Arg95-ClrCGI-Arg95-ClrCGI_Grids < 1"	0.02(#2)	1.32	0.18	0.41	0.3	21
1473-006-0008-01	SM_180#2-Arg95-ClrCGI-Arg95-180#5	0.068(#2, #5)	1.12	0.44	0.54	0.3	40
1473-006-0008-02	SM_180#2-Arg95-ClrCGI-Arg95-180#5_Grids < 1"	0.068(#2, #5)	1.12	0.39	0.48	0.3	37
1473-006-0009-01	SM_180#2-Arg95-180#4-Arg95-i89#6	0.068(#2, #4) 0.149(#6)	1.04	0.42	0.53	0.3	41
1473-006-0009-02	SM_180#2-Arg95-180#4-Arg95-i89#6_Grids < 1"	0.068(#2, #4) 0.149(#6)	1.04	0.38	0.47	0.3	39
1473-006-0010-01	SM_180#2-Arg95-ClrCGI-Arg95-i89#6	0.068(#2) 0.149(#6)	1.22	0.45	0.55	0.3	39
1473-006-0010-02	SM_180#2-Arg95-ClrCGI-Arg95-i89#6_Grids < 1"	0.068(#2) 0.149(#6)	1.22	0.40	0.49	0.3	36
1473-006-0011-01	SM_366#2-Arg95-ClrCGI-Arg95-i89#6	0.02(#2) 0.149(#6)	1.18	0.20	0.45	0.3	25
1473-006-0011-02	SM_366#2-Arg95-ClrCGI-Arg95-i89#6_Grids < 1"	0.02(#2) 0.149(#6)	1.18	0.18	0.40	0.3	24

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)  
[namicertification.com](http://namicertification.com)