

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014667.03  
DATE: 11/08/2022  
CERTIFICATION PROGRAM: Structural  
COMPANY: A Window  
CODE: 412-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>A Window, Inc.</b> <b>6201-C Dowdell Road</b> <b>Fort Worth, TX 76119</b>	<b>Series "PD12 OXXO"</b> <b>Vinyl Sliding Glass Door</b>  Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-3620mm(142.50") H-2019mm(79.50") Panel: W-822mm(32.38") H-1943mm(76.50") DLO: W-806mm(31.75") H-1822mm(71.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG30 3620 x 2019 (143 x 80)-SD</b> <b>Design Pressure: 1440 Pa (30 psf)</b> <b>Positive Design Pressure: 1920 Pa (40 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Pressure: 220 Pa (4.60 psf)</b>

Product Tested By: Molimo, LLC  
Report No: 2498.03-109-12  
Expiration Date: November 30, 2026

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Molimo", written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)