

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015565.17-R1  
DATE: 11/17/2022  
CERTIFICATION PROGRAM: Structural  
COMPANY: Masonite  
CODE: 1823-1  
REVISION DATE: 11/29/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Masonite International</b> <b>1955 Powis Road</b> <b>West Chicago, IL 60185</b>	<b>Series “ Powered &amp; Connected”</b> <b>Inswing Impact Flush-Glazed</b> <b>Fiberglass Side-Hinged Door Assembly</b> <b>w/Glazed Sidelites</b>  Configuration: OXO Glazing: IG-1/8" Tempered Glass/1/8" Heat Strengthened Glass/0.090" PVB Interlayer/1/8" Heat Strengthened Glass Frame: W-2819mm(111") H-2483mm(97.75") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-635mm(25") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-13a/19</b> <b>ASTM E1996-14a/20</b> <b>TAS 202-94</b> <b>(Structural Only)</b>	<b>Design Pressure: ±1915 Pa (±40 psf)</b> <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: American Test Lab, Inc. (ATLNC)  
Report No: ATLNC 0908.01-22/ATLNC 0927.01-21/W-2055  
Expiration Date: October 31, 2026

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)