

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI015606.07</u>
DATE:	<u>11/07/2022</u>
CERTIFICATION PROGRAM:	<u>Structural</u>
COMPANY:	<u>Steves and Sons</u>
CODE:	<u>1846-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Steves and Sons Corporation</p> <p>203 Humble Avenue</p> <p>San Antonio, TX 78225</p>	<p style="text-align: center;">Series "Regency"</p> <p style="text-align: center;">Opaque Inswing Fiberglass</p> <p style="text-align: center;">Side-Hinged Door Assembly</p> <p style="text-align: center;">(with Sidelites)</p> <p style="text-align: center;">Configuration: OXO Glazing: Insulating Glass (Tempered)</p> <p>Frame: W-1740mm(68.50") H-2070mm(81.50")</p> <p>Panel: W-908mm(35.75") H-2013mm(79.25")</p> <p>DLO: W-149mm(5.88") H-1600mm(63.00")</p>

SPECIFICATION	PRODUCT RATING
<p>ASTM E283-04</p> <p>ASTM E330-14</p> <p>ASTM E331-00</p>	<p>Design Pressure: ±2880 Pa (±60 psf)</p> <p>Water Penetration Resistance Test Pressure: 0 Pa (0 psf)</p>

Product Tested By: Testing Evaluation Laboratories, Inc.
 Report No: TEL 01523624 (Specimen 2)
 Expiration Date: October 31, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Email: nami@namiinc.com