NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI015686

DATE: 11/21/2022

CERTIFICATION PROGRAM: Structural

COMPANY: Solar

CODE: <u>872-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Solar Innovations, Inc.	Series "V-2"
31 Robert Road	Aluminum Sliding Glass Door
Pine Grove, PA 17963	w/ Pocket Panel
	Configuration: OXXO Glazing: IG-Exterior-3/16" Tempered Glass/Interior- Laminate 3/16" Annealed Glass/0.090" SentryGlas Plus Interlayer/3/16" Annealed Glass
	Frame: W-6382mm(251.25") H-2481mm(97.69")
	Panels: W-1526mm(60.06") H-2442mm(96.13")
	DLO: W-1422mm(56") H-2267mm(89.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG30 6382 x 2481 (251 x 98)-SD Design Pressure: ±1440 Pa (±30 psf)
	Water Penetration Resistance Test Pressure: 220 Pa(4.59 psf)

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-110-25329-1 Expiration Date: **June 30, 2026**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com