## **NOTICE OF PRODUCT CERTIFICATION**

ACCREDITED		
W ONINL ACCREDITADO	<b>CERTIFICATION NO:</b>	<u>NI015688-R1</u>
Nog Nin An Ing Nam	DATE:	<u>11/07/2022</u>
(NAMI)	<b>CERTIFICATION PROGRAM:</b>	<u>Structural</u>
( The contraction of the contrac	COMPANY:	JELD-WEN
WAGEMENT INSTIT	CODE:	<u>1822-1</u>
ERTIFIED PRODUC	<b>REVISION DATE:</b>	<u>08/31/2023</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	<b>PRODUCT DESCRIPTION</b>	
JELD-WEN	Series "Aurora Custom" Glazed	
3737 Lakeport Boulevard	Fiberglass Inswing Double Side-Hinged Door	
Klamath Falls, OR 97601	(w/Sidelites)	
	Configuration: OXXO Glazing: Tempered	
	Frame: W-3785mm(149") H-3092mm(121.75")	
	Panel: W-1213mm(47.75") H-3016mm(118.75")	
	DLO: W-886mm(34.88") H-2800mm(110.25")	

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class LC PG50 3785 x 3092(149 x 122)-LW SHD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Canadian Air Infiltration/Exfiltration Level : A3

Product Tested By: Report No: Expiration Date: National Certified Testing Laboratories NCTL-310-22-065/NCTL-310-22-081/W-2078 August 31, 2025

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: <u>nami@namiinc.com</u>