

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015689-R1
DATE: 11/09/2022
CERTIFICATION PROGRAM: Fire
COMPANY: Caldera
CODE: 2830-1
REVISION DATE: 08/01/2024
EXPIRATION DATE: 11/30/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Boise Cascade Millwork Products 2980 South Wise Way Boise, ID 83716	20 Minute Fiberglass Reinforced Faced Door w/Proprietary Core (Simulated Panel Type or Flush) Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations Single Door Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10C (2009) CAN4 S104 (1985)	20 Minute-Positive Pressure With Hose Stream Category A - No Additional Edge Sealing Required

TEST REPORT
Intertek Test Report No: J20051379-231, 3084465, 317611MID-002, 3187023MID-002 & 10035435MID-001

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023