

NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI015697-R1
DATE: 11/30/2022
CERTIFICATION PROGRAM: Structural
COMPANY: MP Windows
CODE: 2744-1
REVISION DATE: 01/21/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
MP Windows, Inc. 407 River Heights Circle Anderson, SC 29621	Series "MP-4500 A/B" Thermally-Broken Aluminum Single Hung Window Configuration: O/X Glazing: IG-1/4" Tempered Glass/3/16" Annealed Glass/0.090" Kuraray Trosifol Interlayer/3/16" Annealed Glass Frame: W-1124mm(44.25") H-1911mm(75.25") Panel: W-1051mm(41.38") H-942mm(37.08") DLO: W-1007mm(39.64") H-873mm(34.37")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-12/13a ASTM E1996-12/14a	Class LC-PG65 1124 x 1911 (44 x 75)-H Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 468 Pa (9.75 psf) Wind Zone 3 - Missile Level D

Product Tested By: American Test Lab, Inc.
Report No: NCTL 210-4254-1/W-2056
Expiration Date: September 30, 2030

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023