

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015698.01
DATE: 12/05/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Clayton
CODE: 1983-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Clayton Windows Corporation 1765 Genesis Road Crossville, TN 38555	"5051 SGD" Vinyl Sliding Door Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72") H-2032mm(80") Panel: W-946mm(37.25") H-1962mm(77.25") DLO: W-797mm(31.38") H-1813mm(71.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG45 1829 x 2032* (72 x 80*)-SD Design Pressure: 2160 Pa (45 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 330 Pa (6.89 psf)

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2225T0001.02.01
Expiration Date: **October 31, 2026**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com