

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015699  
DATE: 12/12/2022  
CERTIFICATION PROGRAM: Structural  
COMPANY: Crystal Pacific  
CODE: 2018-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Crystal Pacific Windows Corporation</b> <b>1850 Atlantic Avenue</b> <b>Riverside, CA 92507</b>	<b>Series "Vista Plus Awning"</b> <b>Vinyl Awning Window</b>  Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-914mm(36") Panel: W-1365mm(53.75") H-756mm(29.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG45 1524 x 914 (60 x 36)-AP</b> <b>Design Pressure: ±2160 Pa (±45 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b>

Product Tested By: Intertek, PLC  
Report No: P1473.01-303-44  
Expiration Date: September 30, 2026

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)