

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015702
DATE: 09/18/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: 052-1
REVISION DATE: 12/14/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 1750 Indian Wood Circle Maumee, OH 43537	Series "V-2 Impact FGW 3x8 Panel" Folding Glass Wall w/Panic Hardware Configuration: XXXXXX Glazing: IG-3/16" Tempered Glass/Laminate-3/16" Annealed Glass/0.090" Sentry Glass Plus/3/16" Annealed Glass Frame: W-5665mm(223") H-2553mm(100.5") Panel: W-915mm(36.0) H-2439mm(96.00") DLO: W-737mm(29.00") H-2261mm(89.00")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure = +65/-65 psf Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15135-1/NCTL-110-15005-1
Expiration Date: August 31, 2026

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com