

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015703  
**DATE:** 10/04/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Therma-Tru  
**CODE:** 052-1  
**REVISION DATE:** 12/14/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Therma-Tru Corporation</b> <b>1750 Indian Wood Circle</b> <b>Maumee, OH 43537</b>	<b>Series "V-2"</b> <b>Aluminum Sliding Glass Door</b>  Configuration: OXXX  Glazing: IG-3/16" Tempered Glass/Laminate-3/16" Annealed Glass/0.090" Sentry Glass Plus Interlayer/3/16" Annealed Glass or Monolithic: Laminate-3/16" Annealed Glass/0.090" Sentry Glass Plus Interlayer /3/16" Annealed Glass  Frame: W-6198mm(244")      H-2540mm(100") Panel: W-1537mm(60.5")      H-2515mm(99")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: +65/-65 psf</b> <b>Large Missile Impact Rated</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-15153-1  
Expiration Date: July 31, 2026

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)