

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015708.01
DATE: 12/21/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: 052-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 1750 Indian Wood Circle Maumee, OH 43537	Series "V-3" Aluminum French Door Assembly (w/Standard & High Performance Thresholds) Configuration: XX Glazing: IG-3/16" Tempered Glass/3/16" Annealed Glass/0.090" SentryGlas Plus Interlayer/3/16" Annealed Glass Frame: W-2400mm(94.5") H-2756mm(108.5") Panel: W-1118mm(44") H-2645mm(104.13") DLO: W-921mm(36.25") H-2470mm(97.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG40 2400 x 2756 (95 x 109)-SHD Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-25553-2
Expiration Date: **March 31, 2026**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com