

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015708
DATE: 08/08/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: 052-1
REVISION DATE: 12/14/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 1750 Indian Wood Circle Maumee, OH 43537	Series "V-3" Thermally-Broken Aluminum French Door Assembly w/Standard Threshold Configuration: XX Glazing: IG-3/16" Tempered Glass/5/32" Annealed Glass/0.090" Kuraray SentryGlas Plus Interlayer/5/32" Annealed Glass Frame: W-2426mm(95.5") H-2756mm(108.5") Panel: W-1118mm(44") H-2645mm(104.13") DLO: W-921mm(36.25") H-2470mm(97.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a/14a TAS 201/202/203-94	Class CW-PG40 2413 x 2743 (95 x 108)-SHD Design Pressure: ±1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-19489-1/NCTL-110-19489-2/NCTL-110-19490-2
Expiration Date: **March 31, 2026**

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/Email: nami@namiinc.com