

# Notice of Product Certification

**CERTIFICATION NO.:** 1270-002  
**INITIAL CERTIFICATION DATE:** January 23, 2023  
**REVISION DATE:** N/A  
**REPORT NUMBER:** SPL22001-9-C\_HSOX-P  
**SPECIFICATION:** CSA A440.2-19

**COMPANY:** Rusco Manufacturing  
**CODE:** 1270-1  
**EXPIRATION DATE:** August 31, 2027  
**PRODUCT SIMULATED BY:** Veridis Solutions  
**AIR LEAKAGE REPORT NO.:** AI-04110-E1 Rev.1

**PRODUCT/SERIES NAME:** PVC Single Slider | 9620I-9820I      **OPERATOR TYPE:** HSOX

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1270-002-0001-01	3mm_7/8_8071-arg95-IS20, im	0.082(#2) 0.198(#4)	1.41	0.47	0.57	0.4	35
1270-002-0002-01	3mm_7/8_8071-arg95-IS20, im, Grids<1"	0.082(#2) 0.198(#4)	1.41	0.42	0.50	0.4	33
1270-002-0003-01	3mm_7/8_8071-arg95-IS20, im, Grids>1"	0.082(#2) 0.198(#4)	1.41	0.38	0.44	0.4	30
1270-002-0004-01	GL,3mm_7/8_PCI-arg95-8071, im	0.082(#3)	1.62	0.53	0.59	0.4	34
1270-002-0005-01	GL,3mm_7/8_PCI-arg95-8071, im, Grids<1"	0.082(#3)	1.62	0.47	0.52	0.4	31
1270-002-0006-01	GL,3mm_7/8_PCI-arg95-8071, im, Grids>1"	0.082(#3)	1.62	0.42	0.46	0.4	28

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Administrator's Signature:



National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)  
[namicertification.com](http://namicertification.com)

