

Notice of Product Certification

CERTIFICATION NO.: 1270-004
INITIAL CERTIFICATION DATE: January 23, 2023
REVISION DATE: N/A
REPORT NUMBER: SPL21004-36-C_PRAW-P
SPECIFICATION: CSA A440.2-19

COMPANY: Rusco Manufacturing
CODE: 1270-1
EXPIRATION DATE: October 25, 2026
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-04490-A1 Rev.1

PRODUCT/SERIES NAME: PVC Awning

OPERATOR TYPE: PRAW

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1270-004-0001-01	3mm_7/8_PCI-arg95-8071, im	0.082(#3)	1.54	0.48	0.53	0.1	34
1270-004-0002-01	3mm_7/8_PCI-arg95-8071, im, Grids<1"	0.082(#3)	1.54	0.44	0.48	0.1	31
1270-004-0003-01	3mm_7/8_PCI-arg95-8071, im, Grids>1"	0.082(#3)	1.54	0.39	0.43	0.1	29
1270-004-0004-01	3mm_1 1/4_PCI-arg95-PCI-arg95-8071, im	0.082(#5)	1.22	0.44	0.48	0.1	38
1270-004-0005-01	3mm_1 1/4_PCI-arg95-PCI-arg95-8071, im, Grids<1"	0.082(#5)	1.22	0.40	0.44	0.1	36
1270-004-0006-01	3mm_1 1/4_PCI-arg95-PCI-arg95-8071, im, Grids>1"	0.082(#5)	1.24	0.36	0.39	0.1	33

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. M.' or similar, written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com