

Notice of Product Certification

CERTIFICATION NO.: 1270-005
INITIAL CERTIFICATION DATE: January 23, 2023
REVISION DATE: N/A
REPORT NUMBER: SPL21005-36-C_SF1XD-P
SPECIFICATION: CSA A440.2-19

COMPANY: Rusco Manufacturing
CODE: 1270-1
EXPIRATION DATE: March 18, 2027
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-03741-C1 Rev. 4

PRODUCT/SERIES NAME: PVC Small Fixed OPERATOR TYPE: FIXD

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1270-005-0001-01	3mm_7/8_PCl-arg95-8071, im	0.082(#3)	1.63	0.61	0.68	0.0	40
1270-005-0002-01	3mm_7/8_PCl-arg95-8071, im, Grids<1"	0.082(#3)	1.63	0.55	0.60	0.0	36
1270-005-0003-01	3mm_7/8_PCl-arg95-8071, im, Grids>1"	0.082(#3)	1.63	0.61	0.68	0.0	40
1270-005-0004-01	3mm_1 1/4_PCl-arg95-PCl-arg95-8071, im	0.082(#5)	1.23	0.55	0.62	0.0	45
1270-005-0005-01	3mm_1 1/4_PCl-arg95-PCl-arg95-8071, im, Grids<1"	0.082(#5)	1.25	0.55	0.62	0.0	44
1270-005-0006-01	3mm_1 1/4_PCl-arg95-PCl-arg95-8071, im, Grids>1"	0.082(#5)	1.28	0.55	0.62	0.0	44

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Administrator's Signature:



National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com

