

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011491.09  
DATE: 01/16/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Wincore  
CODE: 1640-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wincore Window Company, LLC</b> <b>250 Staunton Turnpike</b> <b>Parkersburg, WV 26104</b>	<b>Series "8800" Impact-Rated</b> <b>Vinyl Sliding Glass Door</b>  Configuration: XXX Glazing: IG-3/16" Tempered Glass/1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-3645mm(143.50") H-2426mm(95.50") Panel: W-1251mm(49.25") H-2318mm(91.25") DLO: W-1076mm(42.38") H-2159mm(85")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>ASTM E1886-13a</b> <b>ASTM E1996-14a</b>	<b>Class LC-PG50 3645 x 2426 (144 x 96)-SD</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf) <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 02803657/TEL 02803658/NCTL-110-23232-5  
Expiration Date: November 30, 2026

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)