

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015652.02
DATE: 01/27/2023
CERTIFICATION PROGRAM: MFG HSG
COMPANY: Croft
CODE: 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| Croft, LLC 1800 North Clark Avenue Magnolia, MS 39652 | Series "22W" Vinyl Horizontal Sliding Window Configuration: OX Glazing: Insulating Glass (Annealed) Frame: W-1575mm(62") H-889mm(35") Sash: W-764mm(30.06") H-813mm(32") DLO: W-694mm(27.31") H-754mm(29.69") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| AAMA 1701.2-95/17 Federal Manufactured Home Construction & Safety Standard 3280.305 (applicable sub-sections) | Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf |

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2189T0043.01
Expiration Date: Janaury 31, 2025

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com