

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015669.01
DATE: 01/23/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, VA 26104	Series "8400" Vinyl Sliding Glass Door Configuration: XXX Glazing: Insulating Glass (Tempered) Frame: W-3645mm(144") H-2426mm(95.5") Panel: W-1251mm(49.25") H-2318mm(91.25") DLO: W-1076mm(42.38") H-2159mm(85")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG50 3658 x 2438 (144 x 96)-SD Design Pressure: ±2394 Pa (±50 psf) Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 02803552/W-2060
Expiration Date: **July 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com