

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015688.01-R1
DATE: 01/05/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 08/31/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Aurora Custom" Glazed Fiberglass Inswing Double Side Hinged Door (w/Sidelites) Configuration: OXXO Glazing: Ext: 1/8" Tempered Glass/ Int.: Laminated-1/8" Tempered Glass/0.090" Kuraray PVB Interlayer/1/8" Tempered Glass Frame: W-3797mm(149.50") H-3099mm(122") Panel: W-1226mm(48.25") H-3019mm(118.88") DLO: W-962mm(37.88") H-2794mm(110")

SPECIFICATION	PRODUCT RATING
ASTM E1886-19 ASTM E1996-20	Design Pressure: ±2400 (±50 psf) Wind Zone 3-Missile Level D Large Missile Impact Rated

Product Tested By: Intertek, PLC
Report No: P2252.01-301-47/W-2078
Expiration Date: **September 30, 2026**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com