

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015688.03
DATE: 01/05/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Aurora Custom" Glazed Fiberglass Outswing Double Side Hinged Door (w/Sidelites) Configuration: OXXO Glazing: Ext.: 1/8" Tempered Glass/Int.: Laminated-1/8" Tempered Glass/0.090" Kuraray PVB Interlayer/1/8" Tempered Glass Frame: W-3480mm(137") H-2480mm(97.63") Panel: W-1080mm(42.50") H-2438mm(96") DLO: W-806mm(31.75") H-2194mm(86.38")

SPECIFICATION	PRODUCT RATING
ASTM E1886-19 ASTM E1996-20	Design Pressure: ±2400 (±50 psf) Wind Zone 3-Missile Level D Large Missile Impact Rated

Product Tested By: Intertek, PLC
Report No: P2254.01-301-47/P2252.01-301-47
Expiration Date: **September 30, 2025**

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com