

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015711.02
DATE: 01/04/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Linea Rossa
CODE: 2749-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Linea Rossa, LLC 1850 Northwest 84th Avenue, Suite 114 Doral, FL 33126	Series "GLR-U96 & GLR-U97" Aluminum Window Wall System Configuration: OOOO Glazing: Laminated Glass - 1/4" Tempered Glass/0.090" Kuraray PVB Interlayer/ 1/4" Tempered Glass Frame: W-4636mm(182.50") H-3048mm(120") DLO: W-1664mm(65.50") H-2921mm(115")

SPECIFICATION	PRODUCT RATING
TAS 201-94 TAS 202-94 (Structural Only) TAS 203-94	Design Pressure: ±3600 Pa (±75 psf) Large Missile Impact Rated

Product Tested By: QAI Laboratory
Report No: 13195 (Specimen 6)
Expiration Date: **December 31, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com