

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015712.02
DATE: 01/04/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Crystal Pacific
CODE: 2018-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Crystal Pacific Windows Corporation 1850 Atlantic Avenue Riverside, CA 92507	Series "Vista" Vinyl Horizontal Sliding Window Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-3061mm(120.50") H-1535mm(60.44") Panel: W-732mm(28.81") H-1455mm(57.31") DLO: W-1461mm(57.50") H-1438mm(56.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG15 3061 x 1535 (121 x 61)-HS Design Pressure: ± 720 Pa (± 15 psf) Water Penetration Resistance Test Pressure: 140 Pa (2.92 psf)

Product Tested By: Intertek, PLC
Report No: M0561.01-303-44
Expiration Date: **December 31, 2025**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com