NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015716

DATE: 01/11/2023

CERTIFICATION PROGRAM: Structural

COMPANY: Quaker

CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products	Series "V300"
504 Highway 63 South	Vinyl Single Hung Window
Freeburg, MO 65035	
	Configuration: O/X Glazing: Insulating Glass (Annealed)
	Frame: W-1118mm(44") H-1905mm(75")
	Sash: W-1029mm(40.50") H-922mm(36.31")
	DLO: W-1006mm(39.63") H-884mm(34.81")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG50 1118 x 1905* (44 x 75*)-H
AAMA/WDMA/CSA 101/I.S.2/A440-11	Design Pressure: ±2400 Pa (±50 psf)
	Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC

Report No: N7270.02-201-44/N7286.01-201-44

Expiration Date: **November 30, 2026**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com