

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015718.01
DATE: 01/12/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Optimum
CODE: 1742-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Optimum Window Manufacturing, Corp.</p> <p>28 Canal Street</p> <p>Ellenville, NY 12428</p>	<p style="text-align: center;">Series "RTS-430i French Doors"</p> <p style="text-align: center;">Steel Outswing French Doors</p> <p style="text-align: center;">(Rectangle & Curved)</p> <p style="text-align: center;">Configuration: XX</p> <p style="text-align: center;">Glazing: Monolithic-3/16" Heat Strengthened Glass/0.090" SGP Interlayer/3/16" Heat Strengthened Glass</p> <p style="text-align: center;">OR Primary Lite: Monolithic-3/16" Heat Strengthened Glass/0.090" SGP Interlayer/3/16" Heat Strengthened Glass/1/4" Tempered Glass</p> <p style="text-align: center;">AND Secondary Lite: Monolithic-3/16" Heat Strengthened Glass/0.090" SGP Interlayer/3/16" Heat Strengthened Glass</p> <p>Frame: W-2134mm(84") H-3048mm(120")</p> <p>DLO: W-957mm(37.69") H-2910mm(114.56")</p>

SPECIFICATION	PRODUCT RATING
<p>TAS 201/202/203-94</p> <p>ASTM E283-04/12 ASTM E330-14</p> <p>ASTM E331-00/09</p>	<p>Design Pressure: ±3112 Pa (±65 psf)</p> <p>Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf)</p> <p>Large Missile Impact Rated</p>

Product Tested By: Blackwater Technical Services, Inc.
 Report No: BT-OPM-21-001A/BT-OPM-21-001B
 Expiration Date: October 31, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/ Email: nami@namiinc.com